



UTTAR PRADESH JAL NIGAM

WATER - TESTING LABORATORY, JAISINGH PURA, MATHURA

PHYSICAL, CHEMICAL AND BACTERIOLOGICAL TEST - REPORT

Serial No. 25914

Dated, 15 May 2019

Name of Town/Village with Code No. Goverdham

Block / District

Goverdham

Location / Source of Sample

T.W.

Location of the Source

Shri, Krishnam Public School to Sakarwa Road, Gov.

Name and designation of the person responsible to collect the Sample Smt. Laxmi. [Principal]

Date and time of sampling

14.05.2019

Date of analysis

15.05.2019

Parameters	Unit	Test Result	Indian Standards Acceptable Cause of rejection	
------------	------	-------------	---	--

(A) PHYSICAL EXAMINATION

1. Turbidity (NTU)	N.T.U.	2.2	2.50	10
2. Odour		Odour less	Acceptable limit	Unobjectionable
3. pH		6.7	6.50 to 8.50	6.50 to 8.50

(B) CHEMICAL ANALYSIS

1. Total dissolved Solids	mg/lit.	700	500.00	2000.00
2. Chloride (as Cl)	mg/lit.	250	200.00	1000.00
3. Arsenik	mh/lit.	0.0	0.01	0.05
4. Fluoride (as F)	mg/lit.	0.5	1.00	1.50
5. Sulphate (as SO ₄)	mg/lit.	-	200.00	400.00
6. Iron (as Fe)	mg/lit.	0.2	0.30	1.00
7. Nitrate (NO ₃) (as NO ₃)	mg/lit.	25	45.00	45.00
8. Total Hardness (as CaCO ₃)	mg/lit.	400	300.00	600.00
9. Manganese (as Mn)	mg/lit.	-	0.05	0.50

BACTERIOLOGICAL TEST

(C) BACTERIOLOGICAL EXAMINATION

1. Bacteria are		-		
2. Faecal Coliforms	No/100 ml	-	0	0
3. Coliform Organism	No/100 ml	-	0	0

S. Lab Assistant

CHEMIST / JUNIOR ENGINEER

Principal

Shri Krishnam Public School
Sakarwa Road, Goverdham (Mathura)

Manager

Shri Krishnam Public School

Water Testing Laboratory
U.P. Jal Nigam, Jaisingh Pura
MATHURA

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date : 15/01/19

It is certified that an inspection team headed by Munish Paurash Chiketsa Adhikari from Samidayan Swasth Kanya Goverdhan inspected the Shri Krishnam Public School, Sakarwa road, Vill- Sakitara, Goverdhan district- Mathura on 15/01/2019 and found that the Shri Krishnam Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 3 Years.

Signature with Seal :

चिकित्सा अधीक्षक
सानु० स्वा० केन्द्र, गोवर्धन, मथुरा

Name : Munish Paurash,

Designation : Chiketsa Adhikari.

To

Shri Krishnam Public School
Sakarwa road, Vill- Sakitara
Goverdhan district- Mathura

Principal

Shri Krishnam Public School
Sakarwa Road, Goverdhan (Mathura)

Manager

Shri Krishnam Public School